



# UTES Experiences from Sweden



Göran Hellström  
Lund University, Sweden  
NeoEnergy Sweden Ltd




# Closed Loop - Sweden



400,000 Ground-Source Heat Pumps (GSHP) installed  
Ground source supplies 15 % of national heating demand  
30-35 % of all single-family houses has a heat pump

# UNDERGROUND THERMAL ENERGY STORAGE

# Underground Thermal Energy Storage




**ATES** – Aquifer Thermal Energy Storage

Sweden: ca 40 systems



**BTES** – Borehole Thermal Energy Storage


Sweden: ca 50 systems larger than 5000 m drilling



**CTES** – Cavern Thermal Energy Storage


Sweden: 3 systems

# ATES/Open loop - Arlanda Airport



World's largest open loop system –savings 3-4 Gwh electricity, 10-15 Gwh heat  
Payback time 6-7 years

# ATES/Open loop - Arlanda Airport




# BTES - Project Lulevärme, Luleå

## Seasonal storage of waste heat

- Summer: Storage of waste heat from steel plant
- Stored heat: ca 2000 MWh (maximum temp 82 °C)
- Winter: University building heated with/without heat pump
- Extracted heat: 1000-1200 MWh
- In operation 1983-1989

# BTES - Luleå




Borehole heat store: 120 boreholes depth 65 m

# BTES - Luleå




Connection pipes and manifold

# BTES - Luleå




Measured temperature in center of store

# BTES - Luleå



Measured and simulated energy balance 1983-1988

# BTES - Luleå



Estimated ground temperature after charging

Simulation results in good agreement with measurements

# BTES - Project Emmaboda

## Seasonal storage of waste heat

- Summer: Storage of waste heat from foundry
- Stored heat: ca 3600 MWh
- Winter: Factory building heated
- Extracted heat: 2000 MWh
- In operation 2010-

<b>Heat source</b>	<b>Supply temp. (°C)</b>	<b>Direct use</b>	<b>To BTES storage</b>
Directly from ovens	55-70	1 500	1 300
Heat pump produced	60	2 500	2 300
Minor sources	65-70	200	200
<b>Totally</b>	-	<b>4 200</b>	<b>3 800</b>


# BTES - Emmaboda



Borehole heat store: 141 boreholes depth 148,5 m

# BTES Emmaboda

## System layout



# BTES Emmaboda


## Borehole heat exchanger



Open coaxial pipe of polypropylene


# BTES Emmaboda

## Borehole heat exchanger




# BTES Emmaboda

## Connecting pipes



# BTES Emmaboda

## Connecting pipes



The insulation consists of 0.4 m expanded glass (foam glass)



Field manifolds have degassing valves



The BHE with dual pipes and a connection formed as a centralizer


3000 m DN40 polypropylene pipes

14 manifolds

Foam glass insulation

# BTES Emmaboda


## Boreholes



Measurements of borehole deviation

# BTES Emmaboda


## Operation strategy



Heat carrier fluid temperature

# BTES Emmaboda

## First operating experience




Charged energy: 900 MWh (2010), 3000 MWh (2011)

# CTES Lyckebo

- Volume of cavern: 104,300 m<sup>3</sup>
- Storage capacity: 5,5 GWh
- Store temperature 60-90 °C
- Used for seasonal storage
- Cost: 17,5 MSEK (1982)

# CTES Lyckebo



System design


# CTES Lyckebo

Solar  
collector  
field




# CTES Lyckebo

Rock  
cavern  
schematic




# CTES Lyckebo

Rock cavern  
during  
construction



# CTES Avesta

Temperature field




# CLOSED LOOP BOREHOLE HEAT EXCHANGERS

## Astronomy Department, Lund




**BTES heating and free cooling combined with district heating  
Office space 4.900 m<sup>2</sup>**

# Energy load



# Energy supply



# Energy balance

<b>Energy balance</b>	<b>Normal year (adjusted)</b>	
<b>Heat from heat pump</b>		<b>475 MWh</b>
<b>Cold from ground source (free cooling)</b>		<b>155 MWh</b>
<b>Electricity to heat pump compressor</b>		<b>104 MWh</b>
<b>District heating (hot water + peak load)</b>		<b>40 MWh</b>
<b>Electricity to circulationspumps (ground and condensor side)</b>		<b>7 MWh</b>

<b>Key factors</b>	<b>Normal year (adjusted)</b>	
<b>Seasonal performance factor - heat pump (incl. circulation)</b>		<b>4,5</b>
<b>Seasonal performance factor - free cooling</b>		<b>47</b>
<b>Heating and cooling demand</b>		<b>126 kWh/m<sup>2</sup>,yr</b>
<b>Bought energy</b>		<b>28 kWh/m<sup>2</sup>,yr</b>
<b>Seasonal performance factor – ground source (heat pump + free cooling)</b>		<b>5,7</b>
<b>Seasonal performance factor – total (ground source + district heating)</b>		<b>4,4</b>

# Large Swedish BTES


Project	Boreholes	Bore depth (m)	Total (m)
Brf. Ljuskärrsberget, Stockholm Saltsjöbaden	156	230	35880
Kemicentrum (IKDC), Lund	153	230	35190
Lustgården, Stockholm	144	230	33120
Vällingby Centrum, Stockholm	133	200	26600
Brf. Igelbodaplatån, Stockholm Saltsjöbaden	120	200	24000
Kv. Bergen, Stockholm Husby	98	215	21070
ITT Flygt, Emmaboda	140	150	21000
Kv. Galgvreten, Enköping	86	220	18920
Copperhill Mountain Lodge, Åre	92	200	18400
Centrala Gribylund, Täby	87	210	18270
Thulehem, Lund	86	200	17200
IKEA, Uppsala	100	168	16800
NIBE, Markaryd	110	150	16500
Centralsjukhuset, Karlstad	80	200	16000
Backavallen, Katrineholm	91	172	15652
IKEA, Karlstad	100	120	12000
Musikhögskolan, Örebro	60	200	12000
Sjukhuset, Kristinehamn	55	210	11550
Vattenfalls Huvudkontor, Solna	53	200	10600
IKEA, Helsingborg Väla	67	150	10050
Stenungsbaden Yacht Club, Stenungsund	50	200	10000
Näsby Parks Slott, Stockholm	48	180	8640
Projekt Lulevärme, Luleå	120	65	7800

# Hybrid GSHP

- Ground source
- Exhaust air source
- Outdoor air source
- Water source (lake, river)
- Solar source
- Waste heat

# GSHP/Solar hybrid

- Hot water
- Space heating
- Increasing HP evaporator temperature
- Recharging of ground loop



# High-temperature seasonal energy storage



Seasonal storage of solar heat

Examples: Neckarsulm, Germany, and Anneberg, Sweden



# Sea Water



**Hybrid system - Boreholes with summer recharge from lake**

# Combining ground-source for buildings with different load


*Community clusters*



Common ground source

# Combining ground-source for buildings with different load

Avantor-Nydal, Oslo, Norway




# Chemistry Department, Lund



Energy balance by combining buildings with different load profiles

# Heating load




IKDC

Chemistry

## Heating load

Total heat demand	8,5 MW
Heat pump capacity	1,8 MW
- From ground loop	1,2 MW

# Cooling load




Cooling load

Total cooling demand

3,0 MW

# Katrineholm Sport Centre

## *Community clusters*



# IKEA – Applications in Sweden


At present two office/service buildings and six stores are using borehole storage (BTES) or aquifer storage (ATES) for combined heating and cooling

- Distribution Centre, Torsvik, installed 1999 (BTES + horizontal GSHP)
- IKEA Meeting Point in Helsingborg, installed 2003 (BTES)
- IKEA Store in Karlstad, installed 2007 (BTES)
- IKEA Store in Uppsala, installed 2008 (BTES)
- IKEA Store in Malmö, installed 2009 (ATES)
- IKEA Store in Väla, installed 2010 (BTES)
- IKEA Store in Uddevalla, under construction 2012 (BTES)
- IKEA Store in Borlänge, under construction 2012 (BTES)

# IKEA – Applications in Sweden

**General for a 25 000 m<sup>2</sup> store in Swedish climate  
(European system design)**

- 50-60 % of the heat load covered by the HP, represents 85-90 % of the annual heat demand
- Peak load covered by electric boiler, bio fuel burner or DH
- 60 % of the cooling load covered by free cooling from the storage, represents 70-80 % of the annual cold demand
- Peak load covered by running the HP as a chiller. Dry cooler used for disposal of condenser heat



# IKEA – Meeting point 5,000 m<sup>2</sup>, Helsingborg



## Facts:

- 36 boreholes, 140 m deep, single U-pipe
- Heat pump, 90 kW piston compressors
- System heat capacity, 270 kW
- System cooling capacity, 350 kW
- SPF (measured) 6,3

**Pay-back time**  
Expected, 5,5 years (2003)  
Actual, 4,5 years (2007)

# IKEA – Store 25,000 m<sup>2</sup>, Karlstad

## Heat demand

- Max load, 1200 kW
- Energy, 1200 MWh/year

## Cold demand

- Max load, 800 kW
- Energy, 500 MWh/year

## Expectations

- SPF heating, 3.8 (boiler included)
- SPF cooling, 7.3
- Payback time, 6 years



## BTES system installed 2007

- 100 boreholes, 120 m deep, spaced 4,5 m
- Drilled on excavated rock (granite)
- Water filled holes, with single U-pipe
- Construction time 10 weeks (2 rigs)
- High water yields caused problem
- Linked to a 620 kW heat pump/chiller

# IKEA – Store 36,000 m<sup>2</sup>, Uppsala

## Heat demand

- Max load, 1 300 kW
- Energy, 2 200 MWh/year

## Cold demand

- Max load, 1 300 kW
- Energy, 1 500 MWh/year

## Expectations

- SPF heating, 4.3 (boiler included)
- SPF cooling, 6.5 (Americ. design)
- Payback time, 5.5 years



## BTES system installed 2008

- 100 boreholes, 168m deep, spaced 5 m
- 20 m casing through soil into granite
- Water filled holes, with double U-pipes
- Construction time 10 weeks (3 rigs)
- Highly fractured rock caused problem
- Linked to 2 x 660 kW heat pumps/chillers

# IKEA – Store 44,000 m<sup>2</sup>, Malmö

## ATES system installed 2009

- 5 warm and 6 cold wells,
- 90 m deep into a fractured limestone
- Average well capacity, approx. 10 l/s
- Construction time 6 weeks (1 rig)
- Linked to 2 x 410 kW heat pumps/chillers

## Heat demand


- Max load, 1 300 kW
- Energy, 2 350 MWh/year

## Cold demand

- Max load, 1 300 kW
- Energy, 1 450 MWh/annually

## Expectations

- SPF heating, 4.3 (boiler included)
- SPF cooling, 45 (100 %)
- Payback time, 4.5 years



# Karlstad's Hospital, Sweden



Heating and cooling with combined ground and river source

# Karlstad's Hospital, Sweden

Energy demand (=bought energy)

## **BEFORE (2000)**

District heating	26,4 GWh/year
Electricity	23,6 GWh/year
Total	50,0 GWh/year



## **Step 1.** Energy efficiency measures

- Changing windows, improving thermal insulation

## **Step 2.** Change of energy production


- Installation of ground-source heat pump/energy storage with free cooling during summer and preheating of outdoor air during winter

## **AFTER (2011)**


District heating	2,5 Gwh/year
HVAC/GSHP electricity	22,2 GWh/year
Total	24,7 MWh/year

**Savings 24,1 GWh heat (91 %) 1,4 Gwh electricity  
Payback time 5 years**

# Energy supply - before



# Energy supply - after



# Kristinehamn's Hospital, Sweden

Energy demand (=bought energy)

## BEFORE

District heating	2135 MWh/year
HVAC electricity	605 MWh/year
Total	2740 MWh/year



## Step 1. Energy efficiency measures

- Changing windows, improving thermal insulation

## Step 2. Change of energy production

- Installation of ground-source heat pump/energy storage with free cooling during summer and preheating of outdoor air during winter


## AFTER

District heating	155 MWh/year
HVAC electricity	465 MWh/year
Total	620 MWh/year

**Savings 2120 MWh (78 %)**

**Payback time 5 years**

# Kristinehamn's Hospital, Sweden



Bought energy (MWh)

# Installation costs

- Drilling\*                    20-35 EUR per m
- Complete system (borehole heat exchanger, installation, heat pump)  
1500 EUR per kW heating capacity

\*Depending on local geological conditions



Thank you!